

Columbia Valley Water District
6229 Azure Way
Maple Falls, WA 98266
360-599-1699

APPLICATION FOR SERVICE

_____ Date: _____ Account No. _____

Legal Description: _____

Lot: _____ Block: _____ Division: _____ Plat: _____

Service Address: _____

Name (Print): _____

Mailing Address: _____

Telephone: _____

Purpose: () Residential () Commercial () Other _____

Meter Size: _____ Number of Units: _____

NEW SERVICE CHARGES

Meter Installation _____ Installation Fee _____

General Facilities _____ Other _____

TOTAL NEW SERVICE CHARGES _____ **Amount Paid** _____

The undersigned subscriber requests Columbia Valley Water District to supply water service at the premises noted hereon, and agrees to purchase and pay therefore in accordance with the rules and regulations of Columbia Valley Water District.

SUBSCRIBER

SPECIFICALLY, I understand I shall be charged the minimum monthly service charge \$_____ together with charges for all water going through the meter from the date of installation. The rates stated is the rate as of the date this document was signed and may change at any given time in the future. The charges shall then continue until such time as service is no longer required in the opinion of the District and all services provided by the District have been disconnected according to the rules and regulations thereof.

_____ Owner / Representative
Signature

_____ District Representative
Signature

COLUMBIA VALLEY WATER DISTRICT

CHECKLIST

For

WATER AND SEWER SERVICE INSTALLATION

All water and sewer services must be inspected and approved by District personnel before water can be turned on. Only District personnel are allowed to turn on water.

- _____ 1. All fees including the meter fee have been paid.
- _____ 2. Standard application for service has been signed by the property owner.
- _____ 3. Trench depth provides a minimum of 36 inches cover for water and 24 inches for sewer. Separation of water and sewer is ten (10) feet.
- _____ 4. Sewer pipe is minimum 4" diameter PVC D3034-SDR-35 gasket pipe.
- _____ 5. Sewer grades are a minimum of 1% for 6" (1/8" per ft) and 2% for 4" (1/4" per ft)
- _____ 6. Sewer cleanouts are provided for all deflections in the line over 45 degrees.
- _____ 7. All sewer joints are watertight as evidenced by pressure tests or visual inspection by the District.
- _____ 8. Water and sewer pipe has been bedded with sand or pea gravel, 6" on all sides.
- _____ 9. Water line is a minimum of 3/4 inch high moly polyethylene pipe, pressure class 200.
- _____ 10. Water pipe connectors are Ford Pack Joint with stiffeners or equal, no clamps or bands allowed
- _____ 11. Water valves, fittings, connectors, and other accessories are bronze, manufactured by Ford or approved equal.
- _____ 12. As built drawings provided by the contractor showing the location of all pipes, valves, bends and other features are completed. All dimensions must be tied into at least two (2) permanent points such as house corners or power poles.

OWNER

CONTRACTOR

Name: _____

Name: _____

Division: _____

Address: _____

Block and Lot: _____

Telephone: _____

Inspected by: _____

License No: _____

Date: _____